


ÇAP	İŞARET	TOLERANS
Ø 110	m6	+ 0,035 + 0,013
Ø 120	m6	+ 0,040 + 0,015
Ø 130	m6	+ 0,040 + 0,015

	İSİM	TARİH	İMZA	<b>ABH</b> <b>SOMA TERMİK SANTRAL</b> ELEKTRİK ÜRETİM A.Ş.
ÇİZEN	Hasan SEÇKİN			
KONTROL	Fatih Mehmet İŞİK			
ONAY	Subitay ŞENCAN			
ÖLÇEK <b>1:2,5</b>	KÖMÜR HAZIRLAMA OPB 74 TAHRIK TAMBURU			RESİM NO
				<b>2391</b>